



**NOTES:**

**SPECIAL PERMISSION REQUIRED FOR USE OF PLAN 157S.**

SYSTEM WINTERIZATION SHALL ONLY BE ACCOMPLISHED BY A STATE OF NEBRASKA CERTIFIED GRADE 6 WATER OPERATOR. THE WATER OPERATOR SHALL BE ALLOWED, BY VACUUM MEANS, TO REMOVE WATER FROM THE STANDPIPE BY ACCESSING THE BLIND TEE LOCATION.

NO ELBOWS, BENDS, NON-CONCENTRIC REDUCERS, CHECK VALVES, BUTTERFLY VALVES, BACK FLOW PREVENTERS AND/OR PRESSURE REDUCING DEVICES SHALL BE INSTALLED WITHIN FIVE (5) PIPE DIAMETERS UPSTREAM OR FOUR (4) PIPE DIAMETERS DOWNSTREAM OF THE METER SET.

FULL PORT BALL VALVES OR GATE VALVES MAY BE INSTALLED IMMEDIATELY UPSTREAM OF THE METER SET, PROVIDED THEY ARE FULLY OPENED AND NOT USED TO THROTTLE FLOW RATES THROUGH THE METER.

THIS DOCUMENT WAS  
ORIGINALLY SEALED AND  
ISSUED BY LYNN M. MAYHEW  
E-10661, ON 3/20/20018. THIS  
MEDIA SHOULD NOT BE  
CONSIDERED A CERTIFIED  
DOCUMENT AND SHOULD BE  
USED FOR REFERENCE ONLY.