



THIS DOCUMENT WAS
 ORIGINALLY SEALED AND
 ISSUED BY RYAN L. SCHMITZ
 E 3818, ON 1-15-2019. THIS
 MEDIA SHOULD NOT BE
 CONSIDERED A CERTIFIED
 DOCUMENT, AND SHOULD BE
 USED FOR REFERENCE ONLY.

- NOTES:
1. A SERVICE SADDLE SHALL BE REQUIRED FOR ALL 1-1/2" AND LARGER TAPS ON ALL MAINS REGARDLESS OF PIPE THICKNESS CLASS.
 2. USE ADDITIONAL ENLARGED BASE WITH STANDARD 94-E BOX ON ALL 1-1/2" AND 2" CURB STOPS.

<p>CITY OF GRAND ISLAND UTILITIES DEPARTMENT</p>	<p>REVISED: 1/8/2019 DRAWN BY: TDZ CHECKED BY: R.L.S.</p>	<p>1", 1-1/2", OR 2" WATER SERVICE LINE</p>	<p>PLAN 152 1 OF 2</p>
---	---	--	---