



THIS DOCUMENT WAS  
 ORIGINALLY SEALED AND  
 ISSUED BY RYAN L. SCHMITZ  
 E 3818, ON 11-15-2019. THIS  
 MEDIA SHOULD NOT BE  
 CONSIDERED A CERTIFIED  
 DOCUMENT, AND SHOULD BE  
 USED FOR REFERENCE ONLY.

**NOTES:**

1. GRANULAR BACKFILL SHALL BE PLACED IN 3" TO 6" VERTICAL LIFTS AND COMPACTED BY APPROVED MECHANICAL TAMPING DEVICE. MINIMUM EARTH COVER SHALL BE 5'-0".
2. ALL THRUST BLOCKS TO BE TYPE 47-B MODIFIED POURED CONCRETE AS PER DIVISION II; "CONCRETE PAVING SPECIFICATIONS"; AND DIVISION VI "WATER MAINS".
3. ALL CONCRETE BLOCKING SHALL BE INSTALLED IN SUCH A MANNER THAT ALL PIPE AND FITTING JOINTS ARE ACCESSIBLE.